

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.: 11/17 Pargre Dated: 21st Aug 2026

It is certified that an inspection team headed by DR. NIKITA R. PARMAR
(Name of Officers with designation) from PHC Kidana, PHED inspected the S. Poddar
Vidyajyoti (Name & Address of the school) on 21/8/26 (date of inspection) and on
the basis of Water Test Report (Attached) bearing no. 0.2 ppm dated
21/8/26 of Mayur Microlife Laboratory (Name of Laboratory) certified that the
S. Poddar Vidyajyoti (Name of school) has safe drinking water facilities for the students and
members of staff of the institution. School is also maintains the hygienic sanitation condition
in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
This certificate is valid till 21st Aug year 2028

Signature with Seal: 

MEDICAL OFFICER
A.A.M. KIDANA
TA. GANDHIDHAM

Name: Dr. Nikita R. Parmar

Designation: Medical Officer

Name & Address of the Office / Department:

Primary Health Centre Kidana, Village Kidana

To,
The Principal,
S. Poddar Vidyajyoti,
Kidana – Kutch

Note: The certificate is to be issued by authorized officer / PHED Lab / Local bodies



TEST REPORT

Report Issued to **S. PODDAR VIDHYAJYOTI KIDANA**

Lab ID 346/26-27
Report Date 20 Aug. 2026.

Sample collected by self by client
Sample submitted by self by client

Sample collection Date 20 Aug. 2026.
Sample Receipt Date 20 Aug. 2026.
Analysis start Date 20 Aug. 2026.
Analysis complete Date 20 Aug. 2026.

Sample Described as **RO Water**
Marking **Drinking Water**
Mode of packing Packed in plastic bottle
Sample condition Satisfactory

Batch No. NM
Mfg. Date NM
Exp. Date NM
Sample quantity 1000 ml

Sr. No.	Characteristics examined	Unit	BIS Standard	Permissible Limit	Method of Test	Result
			IS 10500 : 2012 Requirement (Acceptable limit)	in the absence of Alternate source		
1	Colour	Hazen Unit	Max 5	Max 15	IS:3025(P-4):1983	< 1
2	Odour	—	Agreeable	—	IS:3025(P-5):1983	Agreeable
3	Turbidity	NTU	1	5	IS:3025(P-10):1984	< 0.1
4	pH	—	6.5 to 8.5	6.5 to 8.5	IS:3025(P-11):1983	6.8
5	Total Dissolved Solids TDS	mg/l	Max 500	Max 2000	IS:3025(P-16):2002	73
6	Total Hardness (as CaCO ₃)	mg/l	Max 200	Max 600	IS:3025(P-21):1983	< 5
7	Calcium Hardness	mg/l	Max 125	Max 350	IS:3025(P-40):1991	< 1
8	Magnesium Hardness	mg/l	Max 75	Max 250	IS:3025(P-46):1994	< 1
9	Chloride (as Cl)	mg/l	Max 250	Max 1000	IS:3025(P-32):1988	30
10	Alkalinity (as HCO ₃)	mg/l	Max 200	Max 600	IS:3025(P-23):1986	10

Remark : Analytical Parameters are satisfactory as per IS 10500:2012 required limit.

End of Report

Mayur Morbia
Dr. Mayur Morbia
PhD Micro, PGMLT

A.A.M. Kidana
MEDICAL OFFICER
A.A.M. KIDANA
TA. GANDHIDHAM

Address

Plot No. TBX - 6, Adipur,
Kutch, Gujarat, India.

Contact

☎ : 722 80 723 80
@ : mayurlabadiipur@gmail.com

Work Hours

Mon to Sat : 8:00 AM to 8:00 PM
Sunday : 8:00 AM to 1:00 PM